



**DISTRICT LEVEL WATER TESTING LABORATORY.**  
**Drinking Water & Sanitation Division, Ramgarh.**



**WATER TESTING REPORT**

Source:-Ground Water

Sample Provided by:-Principal  
Guru Nanak Public School, Ramgarh

Date of Sample Received in District Laboratory:-05/03/2022

Date of Sample Testing in District Laboratory:- 08/03/2022

Location:-Sample No. :- 01-Boring Water

S.N	Testing Parameters.	Value in ppm (mg/L)	BIS - 91&2012 (S.R)
		Sample No. 01	Permissble Limit (mg/L)
01.	Iron as (Fe)	—	0.3-1.0
02.	Fluoride as (F)	—	1.0-1.5
03.	Hardness	80	200-600
04.	Alkalinity	88	200-600
05.	Turbidity	0.5	1-5
06.	Arsenic	0.0	0.01-0.05
07.	pH (Value)	6.63	6.5-8.5
08.	TDS (Total Dissolved Solid)	206	500-2000

*Manoj Kumar Singh*  
Dy. Chairman - Cum - Manager  
Sri Guru Nanak Public School  
Ramgarh

*Raveesh Kumar*  
Chemist  
28/03/22

D.W.&.S. Division, Ramgarh

*Princip*  
PRINCIPAL  
Sri Guru Nanak Public School  
Ramgarh-829122 (Jharkhand)